



NOTE  
 Z= VARIABLE ACCORDING TO WIND ZONES, REFER TO NZBC E2 AS1 TABLE 7 (70mm TYPICAL)

NOTE - RADIUS EDGES TO SUSTRATE - 5MM MIN.

JM SINGLE PLY SEALING MASTIC PLACED ON FLANGE PRIOR TO TPO LAP AND CLAMP

JM TPO MEMBRANE WITH JM APPROVED ADHESIVE

AQUAKNIGHT DRAINAGE OUTLET (RECOMMENDED)

SUBSTRATE BY DESIGN.

TERMINATION BAR REQUIRED ONLY IF NOT USING PARAPET CAP FLASHING

PREFINISHED PARAPET FLASHING BY OTHERS

SUBSTRATE / CLADDING BY DESIGN.

RAINWATER HEAD

FLASHING TAPE LAPS TO SCUPPER PENETRATION - BY BUILDER

1 GUTTER OUTLET / PARAPET

SCALE: NTS



The information and data contained herein are believed to be accurate and reliable. This information does not constitute a warranty and should be used in conjunction with the project specification document supplied by Allco Waterproofing Solutions Ltd. Please contact Allco Waterproofing Solutions Ltd with any questions or deviations from this information.  
 © Allco Waterproofing Solution Ltd

For Technical Advice Contact:  
 Web: [www.allco.co.nz](http://www.allco.co.nz)  
 Email: [info@allco.co.nz](mailto:info@allco.co.nz)  
 Telephone: 09 448 1185  
 Facsimile: 09 448 1186



DRAWN BY: ALLCO	DATE: 10/19
DRAWING REF: T-012C	REV: 1